

---

**TO** Mary Pring  
**REFERENCE** 21/04330/LIPV

---

**FROM** EH Consultation Team, 4<sup>th</sup> Floor, City Hall  
**REFERENCE** 21/018761/EHCT  
**BEING DEALT WITH BY** Anil Drayan  
**TELEPHONE / E-mail** 07931546137 / adrayan@westminster.gov.uk  
**DATE** 22 September 2021

---

**WINGWING, 47 - 49 CHARING CROSS ROAD, LONDON, WC2H 0AN**

**I refer to the application for variation of the Premises Licence for the above premises which is located in the West End Cumulative Impact Zone.**

Following site visits to the premises Environmental Health have no objections to the removal of Conditions 29 and 30 from the Licence.

With regards to Condition 28: In a Cumulative Impact Zone and based on Public Nuisance and Public Safety licensing objectives Environmental Health determines any public capacity on whichever provides the lowest figure based on the following factors:

- Safe Capacity (eg based on means of escape, area of premises etc) and
- Provision of Sanitary Accommodation being in line with BS6465.

In this case the limiting factor is the Sanitary Accommodation provided which are; 4 unisex and one disabled facility. Based on BS6465, Table 10 (restaurant), this equates to a capacity of 120. Condition 28 should therefore be replaced with;

**28. The number of persons permitted in the premises at any one-time (excluding staff) shall not exceed 120 persons.**

No objection is made to the proposed amendment to Condition 11. However Environmental Health considers the proposed changes to conditions 9 and 13 are matters for the Licensing Sub-Committee to determine.

**Anil Drayan**  
**Environmental Health Officer**  
**Environmental Health Consultation Team**  
**Regulatory Support Team 2**